

N42237.AR.000208  
NSB KINGS BAY  
5090.3a

LETTER APPROVING REMEDIATED GROUNDWATER BE TREATED AT WASTEWATER  
TREATMENT SYSTEM NSB KINGS BAY GA  
2/4/1994  
GEORGIA DEPARTMENT OF NATURAL RESOURCES

**Georgia Department of Natural Resources**

205 Butler Street, S.E., East Floyd Tower, Atlanta, Georgia 30334

Reply To:  
 Industrial Wastewater Program  
 Suite 1070  
 404/656-4887

Joe D. Tanner, Commissioner  
 Harold F. Reheis, Director  
 David Word, Assistant Director  
 Environmental Protection Division  
 404/656-4713

February 4, 1994

L. P. Scullion  
 Captain, CEC, USN  
 Public Works Officer  
 Department of the Navy  
 Naval Submarine Base  
 1063 USS Tennessee Avenue  
 Kings Bay, GA 31547-2606

Post-it Fax Note

31547.000

09.01.00.0055

To	Joe Hye		
Co/Dept	Kings Bay		
Phone #		Phone #	404-656-4887
Fax #	912-673-8875	Fax #	404-657-7279

Re: LAS Permit No. GA 03-751

Dear Captain Scullion:

The Georgia Environmental Protection Division acknowledges receipt of your December 30, 1993 letter requesting to tie treated water from groundwater remediation into the sanitary sewer system governed by the referenced permit. As we understand the proposal, this is a pilot-scale testing project which is expected to last up to ten months. Maximum water generated will be 86,400 gpd. Water will be treated to EPA Maximum Contaminant Levels (MCL's).

We are hereby approving the addition of remediated groundwater to the wastewater treatment system for the specified ten month period beginning February 15, 1994. Operation and monitoring of the groundwater remediation will be in accordance with the December 1993 proposal entitled "Request for Authorization for Groundwater Discharge into the NSB Kings Bay Land Application System, Naval Installation Restoration Program, Naval Submarine Base, Kings Bay, Georgia, Contract No. N62467-89-D-0317." You should comply with the pertinent enforcement action by the Hazardous Waste Management Program governing groundwater remediation under the old Camden County Landfill across State Road Spur 40 from the Crooked River Plantation Subdivision. Stipulations contained in the referenced LAS permit will remain the same.

If you have any questions, please contact Mr. Larry Kloet at 404-656-4887.

Sincerely,



Michael S. Creason, P.E.  
 South Unit Coordinator  
 Industrial Wastewater Program

MSC:bk

cc: Madeleine Kellam